Proposal 14773

Overhead doors, Openers, Installation & Repair Service for Various Statewide Maintenance DOT Locations Questions and Responses Set 1

Q1) For the Perry Location Details ask for 3, 14' x12 doors and 2 operators. The opening measure 14w x 12h but the existing doors are 16' high with standard headroom and trolley openers. Do we figure 14 x16 doors and go with 2 new trolley operator and re-hook the operator on the 3rd door?

Or do we figure 14x12 doors high lit to 17'8" and 2 new jack shaft operators? If you go this way you will need a 3rd operator as the existing trolley operator will not work on a high lift door.

- R1) See addendum 1 as there has been a change in quantity and size.
- **Q2)** Each Location has it's own contract and unless it goes over \$50,000.00 a bond is not required correct?
- R2) A Contract will be written to the awarded vendor and it will include all locations they are awarded. Contract award information is in section 4.1 and bonding is in section 2.31
- **Q3)** If we were awarded several locations and the total goes over \$50,000.00 is a bond required.
- R3) If a contractor is awarded several locations and the total cost of these locations meets or exceeds the bonding requirements indicated section 2.31.1 then a bond would apply. Note: the dollar threashold is \$25,000.00.
- Q4) Track DOT is asking for 3" track some locations will not accept 3" track as there is not enough head room, 2" track will have to be used?
- R4) Contractor to bid as per specifications. As per section 3 final door measurements will be needed prior to ordering. Changes will be addressed on an as needed basis.
- Q5) Locks, unless you require a sectional door interlock with doors that have operators and exterior lock should not be used. Locks on manually operated doors are okay.
- R5) Locks, are usually operated manually. However not all locations are this way and we will go by manufacturer recommendations.
- Q6) 14'wide doors are spaced to have a maximum of 4 lites and you can see 3 lights would not space out correctly. Can this be changed to 2 lites or 1 row of lites 24" x8".

Example:

| <u>LITE</u> | <u>SOLID</u> | <u>SOLID</u> | <u>LITE</u> |
|-------------|--------------|--------------|-------------|
| - A 144 | | | |

R6) We need to have a quote for a minimum of 3 lites – 4 is acceptable.

Q7) Can the bid date and the question period be moved out 1 week as this does not give those who are bidding all locations much time to check each location and put the bid together and have it mailed by 9/30/2015.

R7) See Addendum 1